

* "STOP CORONA VIRUS-"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



DELHI JAL BOARD (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



NO: DJB/ACWA(TYR)/2022.....

DATE:- 22-10-2022

Analysis report of DJB supply water samples collected from (1) Inlet and (2) Outlet Bhai Parmanand Vidya Mandir Surya Niketan Nr. Karkardoma Delhi-92 for drinking Purpose.

Date of collection:- 20-10-2022

Challan No-215 dated 18-10-2022

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	-	Clear	Clear
2.	Odour	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	0.83	0.37
4.	pH Value	6.5-8.5	--	-	7.6	7.6
5.	Electrical Conductivity	--	--	µs/cm	405	380
6.	Total Dissolved Solids	500	2000	mg/l	263	247
B.	Chemical Examination					
7.	P th Alkalinity	45	NO RELAXATION	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	102	98
9.	Total Hardness	200	600	mg/l	162	140
10.	Calcium Hardness	mg/l	96	94
11.	Magnesium Hardness	mg/l	66	46
12.	Calcium as (Ca)	75	200	mg/l	38.4	37.6
13.	Magnesium as (Mg)	30	100	mg/l	15.84	11.04
14.	Ammonical Nitrogen	0.5	NO RELAXATION	mg/l	N.D	N.D
15.	Nitrite	mg/l	N.D	N.D
16.	Nitrate	45	NO RELAXATION	mg/l	4.96	4.02
17.	Sulphate	200	400	mg/l	52.70	48.13
18.	Chloride	250	1000	mg/l	36	32
19.	Fluoride	1.0	1.5	mg/l	0.20	0.21
20.	Total Iron	1.0	NO RELAXATION	mg/l	0.16	0.06
21.	Cyanide	0.05	NO RELAXATION	mg/l	N.D	N.D
22.	Residual Chlorine	0.2	1.0	mg/l	1.23	1.0
C.	Bacteriological Examination					
23.	Coliform count	Absent	NO RELAXATION	MPN/ 100ml	0	0

REMARKS:- On the basis of above tested parameters, water samples conforms BIS: 10500-2012 and be considered fit for drinking purpose.

[Signature]
A/CHEMIST

[Signature]
CHEMIST AJAY PAL SINGH
Principal

Bhai Parmanand Vidya Mandir
Surya Niketan, Delhi-110092

[Signature]
22.10.2022
ACWA (TYR)

Asstt. Chief Water Analyst
D.J.B. Govt. of N.C.T. of Delhi
Quality Control Zonal Laboratory (Tyr)
Tahir Pur Dilshad Garden, Delhi-93

MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
SHAHDARA (SOUTH) ZONE
419 1st Floor, UDYOG SADAN
PATPARGANJ INDUSTRIAL AREA DELHI-110092

No. : DHO/Shd.(S)/2024/D-387

Date: 13/9/24


School Health Certificate


1. Name of School	: Bhai Parmanand Vidya Mandir
2. Location of the School	: Surya Niketan, Near Karkardooma Delhi-110092
3. Timing of School	: 7:40 A.M. to 2:00 P.M
4. No. of Staff	: 156
5. No. of Students	: 3428 (Boys 1933 & Girls 1495)
6. No. of Rooms	: 104
7. No. of Doors & Windows In each room	: 4 or 5 in each room
8. No. of Fans in each room	: 4 or 5 in each room
9. No. of Desk & Chair	: Provided in each room
10. No. of Toilets for Boys	: 24
11. No. of Toilets for Girls	: 31
12. : 3 Building Structure	: Pucca
13. Drinking Water	: Provided
14. Electricity	: BSES Supply

At the time of inspection, school is found running under sanitary and hygiene conditions. This certificate has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

The Principal,
Bhai Parmanand Vidya Mandir
Surya Niketan, Near Karkardooma,
Delhi-110092


AJAY PAL SINGH
Principal
Bhai Parmanand Vidya Mandir
Surya Niketan, Delhi-110092


Deputy Health Officer
Shahdara (South) Zone
DEPUTY HEALTH OFFICER
MUNICIPAL CORPORATION OF DELHI
SHAHDARA (SOUTH) ZONE